

**BOQ**

Renovation of Fire Fighting at Dr. Bhupen Hazarika Auditorium and Conference Center of IITG Campus

NIQ No. **IITG/ENGG/20/NIQ/01 Dated: 19.05.2020**

SI.No	Item	Qty	Rate	Unit rate in Word	Amount
1	Supply, testing and fixing of first aid <b>fire hose reel drum</b> wall mounting, swinging type fitted with 25 mm dia ms pipe connection with Jyoti or equivalent make 20mmx30mtr rubber hose with 5 mm outlet gunmetal nozzle with shut off valve.	8 nos			
2	Supply and fixing 63mm dia. <b>15mtr. long RRL hose</b> including male and female instantaneous type coupling, machine wound with copper wire complete in all respects. Hose shall conform to IS 636:88 Type A and coupling to IS 903-1975	8 Nos			
3	Supply and fixing standard short size <b>SS Branch pipe</b> with SS nozzle 16 mm dia. Outlet with standard instantaneous type 63 mm dia. Coupling. ( ISI marked )	8 Nos			
4	Supply and fixing <b>Hose Cabinet</b> 750(W)x250(D)x600(H) The construction of the cabinet to be in 18G CR Sheet with red colour powder coating.	4 Nos			
5	Supply and fixing C.I. <b>butterfly valves</b> PN 1.0 complete with bolts, nuts 3mm thick compressed asbestos gasket companion flanges as per table "E" complete. 80 mm dia.	2 Nos			
6	Supply & fixing of ISI marked <b>4 Kg ABC Type Fire Extinguisher ( As per new BIS )</b>	10 Nos			

**BOQ**

Renovation of Fire Fighting at Dr. Bhupen Hazarika Auditorium and Conference Center of IITG Campus

NIQ No. **IITG/ENGG/20/NIQ/01 Dated: 19.05.2020**

7	Supply & fixing of ISI marked <b>4.5 Kg Co2 Type Fire Extinguisher</b> (Near all Electrical Panels & Office)	8 Nos			
8	Repairing and Painting of Hydrent raiser	8 Nos			
9	Preasure test from all 8 hydrent point, demo and all Hose reel drum check.	Lot			
	<b>TOTAL</b>				
	<b>GST 12 % EXTRA</b>				
	<b>Discount if Any</b>				
	<b>GRAND TOTAL</b>				

Rupees